

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-0026:311 Page 1 of 1

CATEGORY: Misc. Devices/Control Unit Accessories

LISTEE: Simplex, 100 Simplex Drive, Westminster, MA 01441-0001
Contact: Paul Mattern (978) 731-8542

DESIGN: Models 4090-9118 relay IAM (individually addressable module) module, 4090-9119 relay IAM module with unsupervised feedback and 4090-9120 six-point I/O module. (IAM). Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 30 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as control unit accessories for use with Model 4100 (CSFM Listing No. 7165-0026:251 and 7170-0026:250 fire alarm control units.

09-06-2002 BH



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **SEPTEMBER 6, 2002**

Listing Expires June 30, 2003

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager